



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)785-1020

<u>FOR OFFICE USE ONLY</u>
Facility # 1-015668
Permit # 01014-2013UPG
Request Rec'd 10/03/2013
Amended Date
Approval Date 10/4/2013 JC
Permit Expires 4/4/2014

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Johnson Oil Company          1305 12th Avenue          Rock Falls, IL 61071</p> <p>Contact: Arthur J. Johnson (815) 625-6380</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Express Lane Gas &amp; Food Mart          342 North Mason          Amboy, Lee Co., IL</p> <p>Contact: Sandy Richard (815) 857-2990</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 5) - 8,200 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 5) - (Installing) Dispenser Sump containment FRP for the new dispenser location only, (TK # 5) - (Installing) Submersible Sump containment FRP for this tank only, (TK # 5) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC from the existing submersible to the new dispenser location only.
- (d) *Product to be stored in each tank:* (TK # 5) - Diesel Fuel
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:* (TK # 5) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS at the submersible sump and at the new dispenser sump only.
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 5) - (Installing) Flexible Non-Corrosive from the existing submersible to the new dispenser location only.
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Illowa Enterprises, Inc.          2703 4th Avenue          Moline, IL 61265</p>	<p>Contact Person: Rob Vyncke          Phone: (309) 762-1729</p> <p>Contractor Registration # IL-981 Exp. 05/01/2014</p>

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Division File  
 (Rev. - 9/10)