



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-007979
Permit # 00783-2012INS
Request Rec'd 08/02/2012
Amended Date
Approval Date 8/3/2012 JC
Permit Expires 2/3/2013

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: I-55 Truckstop Properties LLC 510 S. Bolingbrook Drive Bolingbrook, IL 60440 Contact: John Puthusseril (630) 739-7006	(2) FACILITY - name and address where tanks are located: Greater Chicago I-55 Truck Plaza 510 South Bolingbrook Drive Bolingbrook, Will Co., IL Contact: John Puthusseril (630) 739-7006
---	---

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** One compartment tank consisting of: (TK # 17) - 12,000 gallons, (TK # 18) - 8,000 gallons
- (b) **Type of tanks:** (TK # 17, 18) - (Installing) Fiberglass Double Wall Containment Solutions (compartment tank).
- (c) **Type of piping:** (TK # 17, 18) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from the submersible of tank #17 to a dispenser / blending metering device, then to the northern most -per site plan- set of existing submersible sumps at tanks #13 and #14 to complete the bio-diesel injection / blending system as shown on site plan. There will also be a piping run installed from the submersible pump of tank #18 to a new dispenser as shown on site plan (this dispenser will be for non-regulated DEF and possibly CNG in the future).
- (d) **Product to be stored in each tank:** (TK # 17) - Bio-Diesel, (TK # 18) - Diesel Exhaust Fluid (Non-Regulated)
- (e) **Type of leak detection being used:**
Tank: (TK # 17, 18) - (Installing) Interstitial Monitoring Veeder Root TLS 350 , (TK # 17, 18) - (Installing) Automatic Tank Gauging Veeder Root TLS 350
Piping: (TK # 17) - (Installing) Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D (contractor states there will not be a line leak detector installed for the DEF #18 tank at present , (TK # 17, 18) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the submersible sumps for tanks 17 and 18, at the northern most -per site plan- submersible sumps for tanks 13 and 14 (tanks 13 and 14 actually have two existing submersible pumps for each tank), and at the new bio-diesel dispenser / blending pump sump. Contractor has elected not to install a dispenser sump sensor at the new DEF / CNG dispenser.
- (f) **Corrosion Protection being used:**
Tank: (TK # 17, 18) - (Installing) Fiberglass Non-Corrosive
Piping: (TK # 17, 18) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping and dispenser containment devices:** (TK # 17, 18) - (Installing) Manhole Pre-manufactured OPW 1-2100
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

- (6) **SPECIAL CONTINGENCIES:**

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Brian McCormick Phone: Contractor Registration # IL-002329 Exp.
--

Sincerely,

A handwritten signature in cursive script, reading "James J. Coffey", is written over a horizontal line.

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)