



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-011004
Permit # 00656-2012UPG
Request Rec'd 07/09/2012
Amended Date
Approval Date 7/10/2012 DS
Permit Expires 1/10/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois Toll Highway Authority One Authority Drive, 2700 Ogden Avenue Downers Grove, IL 60515 Contact: John Wagner (708) 505-0703	(2) FACILITY - name and address where tanks are located: ISTHA M04 Maintenance Garage Grand Avenue & 294, Tri-State Tollway, Mile Post 69 Gurnee, Lake Co., IL Contact: Tom Pfleege (630) 241-6800
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Fiberglass Single Wall Vent Piping Ameron, (TK # 1, 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank: (TK # 1, 2) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 with CSLD
Piping: (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in new tank sumps, new dispenser sumps and in new Diesel transition sump, (TK # 1, 2) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 1, 2) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 1, 2) - (Installing) Manhole Pre-manufactured OPW 1C-2100C-DEVR
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Rockford, IL 61104	Contact Person: Phone: (815) 398-6250 Contractor Registration # Exp.
---	---

Sincerely,

Daniel Starks

