



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 2-001581
Permit # 00361-2012UPG
Request Rec'd 04/17/2012
Amended Date 05/29/2012
Approval Date 4/17/2012 JC
Permit Expires 10/17/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Village of Morton Grove 6101 Capulina Avenue Morton Grove, IL 60053 Contact: Paul Tobin (312) 965-4100	(2) FACILITY - name and address where tanks are located: Morton Grove Public Works 7840 Nagle Avenue Morton Grove, Cook Co., IL Contact: Paul Toben (847) 470-5236
--	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 2) - 12,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 1) - (Installing) **Fiberglass Single Wall vent Piping**, (TK # 1, 2) - (Installing) Flex Connector Steel at the dispensers only, along with the installation of new European suction pumps, **to also include extractor fittings for future verification of European suction piping.** The contractor is also replacing any underground and above ground vent piping as necessary, per original site plan. (TK # 1) - (Installing) **Fiberglass Double Wall Ameron product piping to replace the existing run.**

(d) *Product to be stored in each tank:* (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 2) - (Installing) Sacrificial Anode Cathodic Protection as necessary at the diesel dispenser only (for any unprotected steel fittings / flex connectors / components).

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Wheeling, IL 60090-3906	Contact Person: Phone: (847) 465-4000 Contractor Registration # Exp.
--	--

Sincerely,

Jim Coffey

