



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-007199
Permit # 00469-2012ABN
Request Rec'd 05/11/2012
Amended Date
Approval Date 5/14/2012 JC
Permit Expires 11/14/2012

Section of piping only

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Farah Mohammad 1361 Argyle Lane Bourbonnais, IL 60914 Contact: Farah Mohammad (815) 932-0241	(2) FACILITY - name and address where tanks are located: Marathon GNS Corporate 1815 East Court Street Kankakee, Kankakee Co., IL Contact: Farah J. Mohammad (815) 932-0241
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

(a) Number and size tanks being abandoned: (TK # 6) - 10,000 gallons

(b) Location of tanks being abandoned: Tanks will remain. **Only a section of piping is to be abandoned (see contingencies section) CONTAMINATED SITE! IEMA Number: H20120432**

(c) Location of piping being abandoned: *See contingencies section and site plan.*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) SPECIAL CONTINGENCIES: **This abandonment is for a section of piping only. The section to be abandoned is from the new air bleed off riser located on the site plan, to dispensers 5/6 and 7/8 (this section of piping runs within an active piping trench. The piping before the air bleed off will remain active to supply dispensers 1/2 and 3/4. See permit #00468-2012UPG for further information on this activity. Inspector should verify if there is more steel product piping at this site and what type of corrosion protection is being used.**

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: (708) 474-3344 Contractor Registration # IL-1207 Exp. 06/06/2013
--	---

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)