



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-041586
Permit # 00411-2012UPG
Request Rec'd 04/25/2012
Amended Date
Approval Date 4/25/2012 DS
Permit Expires 10/25/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Costco Wholesale 999 Lake Drive Isaquah, WA 98027 Contact: Dennis Bock (425) 313-6048	(2) FACILITY - name and address where tanks are located: Costco Wholesale 1332 South Route 59 Naperville, Du Page Co., IL Contact: Booby Miller (419) 691-7474
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 20,000 gallons, (TK # 4) - 1,500 gallons
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Lubrizol - Fuel Additive
- (e) Type of leak detection being used:*
 - Tank:** (TK # 1, 2, 3, 4) - (Installing) SIR and Prec Tightness Testing Veeder Root BIR business inventory reconciliation to existing TLS350 console
 - Piping:**
- (f) Corrosion Protection being used:*
 - Tank:**
 - Piping:**
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Mokena, IL 60448	Contact Person: Phone: (708) 478-6190 Ext. 231 Contractor Registration # Exp.
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)