**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**
**Division of Technical Services**
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-024383
Permit # 00395-2012CAT
Request Rec'd 04/25/2012
Amended Date
Approval Date 4/25/2012 DS
Permit Expires 10/25/2012

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

| **(1) OWNER OF TANKS** - Corporation, partnership, or other business entity: | **(2) FACILITY** - name and address where tanks are located: |
|---|---|
| The Premcor Refining Group, Inc. c/o Valero Energy Corporation<br><br>One Valero Way<br>San Antonio, TX 78146-5122<br><br>Contact: Property Assets (210) 345-4262 | Grayslake Stop & Shop, LLC<br>735 E. Belvidere Road<br>Grayslake, Lake Co., IL<br><br>Contact: Louay Alani (847) 223-6015 |

**(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

***(a) Number and size of tanks having cathodic protection installed, upgraded, or repaired:*** (TK # 1, 2) - 12,000 gallons, (TK # 3) - 10,000 gallons, (TK # 4, 5) - 6,000 gallons

***(b) Type of tanks:***

***(c) Type of piping:***

***(d) Product to be stored in each tank:*** (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel, (TK # 5) - Kerosene

***(e) Type of leak detection being used:***

***Tank:***

***Piping:***

***(f) Corrosion Protection being used:***

***Tank:***

***Piping:*** (TK # 1, 2, 3, 4, 5) - (Installing) Sacrificial Anode Cathodic Protection to replace failed anodes on EXISTING Impressed Current system and repairing cables if necessary.

***(g) NACE certified designer: Tim Sievert*** ***Certification number:*** 5008

***(h) Method of integrity assessment of tank(s) being used:***

**(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES**:

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK**:

Contact Person: Timothy J Sievert
Phone:

Contractor Registration # IL-2072 Exp.

Sincerely,

Daniel J. Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)