



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 4-024279
Permit # 00369-2012UPG
Request Rec'd 04/19/2012
Amended Date
Approval Date 4/19/2012 JC
Permit Expires 10/19/2012

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company        One Convenience Boulevard, P.O. Box 3001        Ankeny, IA 50021-8045</p> <p>Contact: Jill Reams-Widder (515) 965-6238</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Casey's General Store        301 South Market Street        Monticello, Piatt Co., IL</p> <p>Contact: Jill Reams-Widder (217) 762-8121</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 6,000 gallons, (TK # 2) - 10,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC to replace all existing product piping. , (TK # 1, 2) - (Installing) Submersible Sumps containment FRP at each submersible pump, (TK # 1, 2) - (Installing) Dispenser Sumps containment FRP under each dispenser.
- (d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) **Type of leak detection being used:**  
**Tank:**  
**Piping:** (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at each submersible sump and at each dispenser sump. Existing line leak detectors to be re-used.
- (f) **Corrosion Protection being used:**  
**Tank:**  
**Piping:** Installing non-corrosive flexible piping for tanks 1 & 2.
- (g) **Spill containment devices, piping, and dispenser containment devices:** (TK # 1, 2) - (Installing) Manhole Pre-manufactured EBW 705
- (h) **Overflow prevention devices:**
- (i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Washington, IL 61571</p>	<p>Contact Person: Tom Oltman        Phone:        Contractor Registration # IL-1079 Exp.</p>
--	---

Sincerely,

*James J. Coffey*

