



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-044885  
Permit # 00256-2012ABN  
Request Rec'd 03/21/2012  
Amended Date  
Approval Date 3/22/2012 JC  
Permit Expires 9/22/2012

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Pelron Corporation 7847 W. 47th Street McCook, IL 60525  Contact: Eric Lacey	<b>(2) FACILITY</b> - name and address where tanks are located:  Pelron Corporation 7847 W. 47th Street McCook, Cook Co., IL  Contact: Douglas Lindsay
---	--

**(3) ABANDONMENT IN PLACE OF TANKS:**

**(a) Number and size tanks being abandoned:** (TK # 4) - 1,100 gallons

**(b) Location of tanks being abandoned:** CONTAMINATED SITE! IEMA Number: 2012-0192

**(c) Location of piping being abandoned:** *See contingencies section.*

**(4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

**(5) SPECIAL CONTINGENCIES:** Tank being filled with concrete slurry. Permit application states the associated piping can physically be removed (contractor states this is a very short minimal amount of piping localized in the immediate tank area). Contractor is allowed to remove this small amount of piping (without a separate removal permit) since it is very short, localized, and a recent site assessment with soil boring locations are on file. The UST is adjacent to a building on two sides, and adjacent to an electrical pole which cannot be safely held in place to allow safe removal of tank.

**(6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>  Petroleum Technologies Equipment, Inc. 8447 West 44th Place Lyons, IL 60534	Contact Person: Thomas J JR Doherty Phone: (708) 579-9189 Ext.  Contractor Registration # IL-2051 Exp.
---	---

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)