



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
 Facility # 5-009415
 Permit # 00243-2012ABN
 Request Rec'd 03/16/2012
 Approval Date 3/19/2012 JC
 Permit Expires 9/19/2012

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Campbell, Essa Jane 303 W. Second Assumption, IL 62510 Contact: Michael L. Corzine</p>	<p>(2) FACILITY - name and address where tanks are located: Essa Jane Campbell 115 N. Business 51 Assumption, Christian Co., IL Contact: Michael L. Corzine (217) 454-3237</p>
---	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 3) - 2,000 gallons
- (b) *Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 20120134
- (c) *Location of piping being abandoned:* **See site plan and contingencies section.**

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) **SPECIAL CONTINGENCIES: The tank is between and under two existing buildings. Associated piping is being abandoned also. Tank will be filled with inert material. Site assessment report form is on file. Refer also to permit #00160-2012REM.**

(6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>JK-Five Construction, Inc. 2160 E. Enterprise Springfield, IL 62702</p>	<p>Contact Person: Ron Williams Phone: (217) 391-2656 Contractor Registration # IL-002378 Exp. 05/26/2013</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)