



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 5-020604
Permit # 01269-2011CAT
Request Rec'd 12/28/2011
Amended Date 02/29/2012
Approval Date 12/28/2011 JC
Permit Expires 6/28/2012

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:

Casey's Retail Company
One Convenience Boulevard, P.O. Box 3001
Ankeny, IA 50021-8045

Contact: Jill Reams-Widder (515) 965-6238

(2) FACILITY - name and address where tanks are located:

Casey's General Store #2937
1133 W. Jefferson
Springfield, Sangamon Co., IL

Contact: Jill Reams Widder (217) 546-0975

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 1, 2, 3) - 10,000 gallons, (TK # 4, 5) - 8,200 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline, (TK # 4) - Diesel Fuel, (TK # 5) - Kerosene

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 1, 2, 3, 4, 5) - (Installing) Sacrificial Anode Cathodic Protection to any exposed metal components / fittings / flex connectors **under all dispensers at this facility**, and at the submersible sump for tank #5 only. The facility records indicate the product piping is all single wall fiberglass.

(g) *NACE certified designer:*

Certification number:

(h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Danville, IL 61834

Contact Person:

Phone: (217) 443-2263

Contractor Registration # Exp.

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)