



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

## Piping removal only

FOR OFFICE USE ONLY  
Facility # 3-017711  
Permit # 00155-2012REM  
Request Rec'd 02/21/2012  
Amended Date  
Approval Date 2/22/2012 JC  
Permit Expires 8/22/2012

**Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071  Contact: Arthur J. Johnson (815) 625-6380	<b>(2) FACILITY</b> - name and address where tanks are located:  Express Lane #69 306 N. Canal Street Annawan, Henry Co., IL  Contact: Bhola Sidhu (309) 935-5588
---	---

**(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 6) - 6,000 gallons
  - (b) *Description/location of piping being removed:* **See site plan and contingencies section.**
  - (c) *Product stored in each tank:* (TK # 6) - Diesel Fuel
  - (d) *Reason of tanks being removed:* **Tank will remain**
  - (e) *If tank(s) is leaking, indicate IEMA incident number:*
  - (f) *Date each tank was last used:* (TK # 6)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** This permit is for limited piping removal only (the dispenser that is closest to the building will be removed along with associated piping running between that dispenser and the one next to it). The tank will remain. Also, reference permit #00156-2012UPG for further reference to this job. A copy of the original site plan for tanks 5,6,7 is enclosed with this permit to reference the original piping layout for tank #5 (If the piping for tank #5 has been altered, or needs to be once this job begins, an amended site plan will need to be submitted to show the correct piping layout from tank #5 to the dispenser islands). Depending on comparison of the original site plan and this latest upgrade site plan, it is possible the piping to be removed originated from tank #5 as opposed to tank #6.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Illowa Enterprises, Inc. 2703 4th Avenue	Contact Person: Rob Vyncke Phone:  Contractor Registration #    Exp.
--	---

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)