



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-011428
Permit # 00073-2012UPG
Request Rec'd 01/24/2012
Amended Date
Approval Date 1/25/2012 JC
Permit Expires 7/25/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Dugan Oil Company P.O. Box 207, Main Street Loami, IL 62661 Contact: John Norris (800) 243-1533	(2) FACILITY - name and address where tanks are located: Dugan Oil Company 624 East Morton Avenue Jacksonville, Morgan Co., IL Contact: John Norris (217) 624-3402
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:** (TK # 2) - 4,000 gallons, (TK # 5) - 2,000 gallons
- (b) Type of tanks:**
- (c) Type of piping:** (TK # 2, 5) - (Installing) partial Fiberglass Single Wall Piping to accommodate the conversion of fuel types for these two tanks. There will only be short sections of piping installed for these two tanks in the localized area within the tank field to accommodate this conversion of fuel storage and delivery to the existing dispensers. The product line coming from tank #2 will be cross connected to the existing line that serves the dispensers that were originally served by tank #5, and the product line coming from tank #5 will be crossed into the existing line that serves the dispensers that were originally served by tank #3. The existing line that originally served the dispensers for tank #2 will be removed, along with tank #3, and along with old existing piping that used to be served by tank #4 leading from the tank field to the dispensers through permit #00072-2012REM (see the contingencies section and the site plan for further details).
- (d) Product to be stored in each tank:** (TK # 2) - Gasoline, (TK # 5) - Diesel Fuel
- (e) Type of leak detection being used:**
 - Tank:**
 - Piping:**
- (f) Corrosion Protection being used:**
 - Tank:**
 - Piping:**
- (g) Spill containment devices, piping, and dispenser containment devices:**
- (h) Overfill prevention devices:**
- (i) Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Springfield, IL 62707	Contact Person: Howard Tuttle Phone: Contractor Registration # IL-1949 Exp.
--	---

Sincerely,

