



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 6-011105
Permit # 01261-2011UPG
Request Rec'd 12/27/2011
Amended Date
Approval Date 12/30/2011 JC
Permit Expires 6/30/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Moto, Inc. 721 West Main Street, P. O. Box 122 Belleville, IL 62222-0122 Contact: Rob Whittington (618) 233-6754 Ext. 106	(2) FACILITY - name and address where tanks are located: Village Motomart 721 North Bluff Road Collinsville, Madison Co., IL Contact: Joe Hooten (618) 233-6754
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4) - 20,000 gallons, (TK # 5, 6) - 6,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 3, 4) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P150SC to accommodate the disconnection of the existing siphon bar, and the installation of a submersible pump in tank #4 (the existing siphon will be disconnected and used as a chase pipe to accommodate the installation of the piping for the new submersible pump in tank #4 and to accommodate the minor reconfiguration of the existing manifolded piping from tank #3). There will be a minor alteration of the existing piping manifold from tank #3 that will be re-configured to result in Tank #4 supplying five dispensers, and tank #3 will supply four dispensers **(see the enclosed copy of the original installation site plan for these tanks and piping for better reference)**, (TK # 4) - (Installing) submersible pump

(d) Product to be stored in each tank: (TK # 1, 3, 4) - Gasoline, (TK # 2) - Diesel Fuel, (TK # 5, 6) - Kerosene

(e) Type of leak detection being used:

Tank: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Automatic Tank Gauging Incon TS 550 with SCALD monitor and probes to replace the existing ATG system.

Piping: (TK # 1, 2, 3, 4, 5, 6) - (Installing) Electronic Pressurized Line Leak Detection Incon TSLS 500, (TK # 1, 2, 3, 4, 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS at all submersible sumps only.

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Saint Louis, MO 63102	Contact Person: Terry Smith Phone: Contractor Registration # IL-246 Exp.
--	--

Sincerely,

