



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-014582
Permit # 01271-2011UPG
Request Rec'd 12/29/2011
Amended Date
Approval Date 12/29/2011 JC
Permit Expires 6/29/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501-1500 Contact: Michelle McKee (937) 864-3000	(2) FACILITY - name and address where tanks are located: Speedway #7568 499 W. Boughton Bolingbrook, Will Co., IL Contact: Dave Nycz (630) 759-1950
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 10) - 20,000 gallons, (TK # 11) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 10, 11) - (Installing) Dispenser Sump containment FRP to replace the existing dispenser sump # 3/4 only - due to fire damage, (TK # 10, 11) - (Installing) partial primary Flexible Double Wall A.P.T. Poly Tech P175SC from the submersible sump of tank #11 all the way through to dispensers #1/2 and # 3/4 to replace fire damaged piping. Partial primary product piping will also be replaced between dispensers 1/2, 3/4, and 5/6 only - to replace fire damaged piping. Contractor states there is existing 4" secondary chase piping for the primary product piping.

(d) *Product to be stored in each tank:* (TK # 10, 11) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 10, 11) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 to replace the existing fire damaged sensor at dispenser sump # 3/4 only. Contractor states there are existing sensors at all other associated dispenser sumps and submersible sumps.

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 10, 11) - (Installing) partial Flexible Non-Corrosive. The primary piping is also contained within fiberglass 4" chase duct.

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Chicago Heights, IL 60411	Contact Person: Doug Harmon Phone: Contractor Registration # IL-194 Exp.
--	--

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)