



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 6-000333
Permit # 01029-2011UPG
Request Rec'd 10/19/2011
Amended Date
Approval Date 10/21/2011 JC
Permit Expires 4/21/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Frey Management, LLC 13762 Frey Acres Drive Highland, IL 62249 Contact: Lori Frey	(2) FACILITY - name and address where tanks are located: Frey's Country Store 916 6th Street Highland, Madison Co., IL Contact: Mary Frey (618) 654-3334
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 6) - 6,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 6) - (Installing) Flex Connector Steel at the submersible sump to replace the existing leaking sensor only, (TK # 6) - (Installing) Submersible Sumps containment FRP
- (d) Product to be stored in each tank:* (TK # 6) - Gasoline
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:* (TK # 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Franklin Fueling Systems S404 sump sensor at the submersible sump only.
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Saint Louis, MO 63139	Contact Person: Greg Spiros Phone: Contractor Registration # IL-1910 Exp.
--	---

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)