



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-013100  
Permit # 00936-2011ABN  
Request Rec'd 09/22/2011  
Amended Date  
Approval Date 10/18/2011 JC  
Permit Expires 4/18/2012

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Dany Investment, LLC 827 Lewisburg Lane Aurora, IL 60504  Contact: Shabbir Kisat (847) 791-1930	<b>(2) FACILITY</b> - name and address where tanks are located:  Arrowhead Citgo 19 North 479 Route 20 Hampshire, Kane Co., IL  Contact: Mgr. (847) 683-2060
--	--

**(3) ABANDONMENT IN PLACE OF TANKS:**

- (a) Number and size tanks being abandoned:* (TK # 10) - 4,000 gallons
- (b) Location of tanks being abandoned:* See site plan and contingencies section.
- (c) Location of piping being abandoned:* See site plan and contingencies section.

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES:** Site assessment is on file. Tank to be filled with flowable fill, slurry concrete. < 50lbs. of cement per cubic yard. The tank to be abandoned is between a canopy column base and the remainder of the active tank field which consists of two 10,000 gal. and one 20,000 gallon tanks. Any piping associated with tank #10 must be abandoned in place, or if it can physically be safely removed - then it must be removed.
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b>  Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Jim Veverka Phone: (815) 398-6250  Contractor Registration # IL-1890 Exp.
--	--

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)