



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-044952
Permit # 00973-2011ABN
Request Rec'd 09/30/2011
Amended Date
Approval Date 10/3/2011 JC
Permit Expires 4/3/2012

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Archdiocese of Chicago 155 East Superior Chicago, IL 60611 Contact: Dave Boivin (773) 385-5051	(2) FACILITY - name and address where tanks are located: St. Pius X Church 4300 Oak Park Ave. Stickney, Cook Co., IL Contact:
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 1) - 5,000 gallons
- (b) Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 20110884
- (c) Location of piping being abandoned:*

(4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.

(5) SPECIAL CONTINGENCIES: See also permit # 00782-2011ABN (the previous permit was denied based on a site plan that did not show any justification for removal). This new current permit #00973-2011ABN was justified in the field by Randy Carben on 09/30/11. Mr. Carben visually inspected this site and said removing the tank could undermine an existing chimney and basement retaining wall at this site. He also confirmed this site address as 4300 Oak Park Ave. The tank will be filled with low strength slurry mix.

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> R. W. Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Alisa C Anderson Phone: (708) 458-6868 Contractor Registration # Exp.
---	--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)