

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL **Division of Technical Services**

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 1-024482 Permit # 00959-2011UPG Request Rec'd 09/29/2011 Amended Date Approval Date 9/30/2011 JC Permit Expires 3/30/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Sapp Bros., Inc. 9915 S. 148th Street Omaha, NE 68138	Sapp Bros. Travel Centers, Inc. 3130 May Road Peru, LaSalle Co., IL
Contact:	Contact: Kevin Cassidy (815) 224-1065

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) 12,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2, 3) (Installing) Dispenser Sumps containment FRP at all four existing dispensers and at the two new dispensers, (TK # 1, 2, 3) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX for the new remote fill piping, and for the two new additional dispensers, (TK # 1, 2, 3) - (Installing) partial Fiberglass Single Wall Piping Ameron only for the adjustment of positions for the four existing dispensers. These existing dispensers will be adjusted so they are located parallel with the canopy instead of the present 30 degree angle to the canopy. The short sections of single wall piping is therefore only to accommodate this adjustment in the localized area of these existing dispensers, (TK # 1, 2, 3) - (Installing) Submersible Sumps containment FRP for each tank, and a new tank sump at each tank for the new remote fills.
- (d) Product to be stored in each tank: (TK # 1) E-85, (TK # 2, 3) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping: (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at the remote fill tank sumps, at each submersible sump, and at the two new dispenser sumps only. There will NOT be sensors installed at the four existing dispensers. Contractor states there are existing line leak detectors.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1, 2, 3) - (Installing) partial Fiberglass Non-Corrosive

- (g) Spill containment devices, piping, and dispenser containment devices:
- (h) Overfill prevention devices: Contractor indicates there is an existing overfill alarm.
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) <u>SPECIAL CONTINGENCIES</u> :	Interstitial sensors must abide by section 175.640 (a)(2).		
(6) PERSON, FIRM OR COMPANY PERFORMING WORK:			
	Contact Person: Phone:		
Pekin, IL 61554	Contractor Registration # Exp.		

James of Coffey

Sincerely,

Fire Department -Office Coordinator -Division File (Rev. - 9/10)