



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 5-006066
Permit # 00920-2011ABN
Request Rec'd 09/15/2011
Amended Date
Approval Date 9/16/2011 JC
Permit Expires 3/16/2012

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Mini Express, Inc.          900 East Laurel Street          Springfield, IL 62702          Contact: Anwar Okbah (217) 528-1077</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Mini Express, Inc.          900 East Laurel Street          Springfield, Sangamon Co., IL          Contact: Anwar Okbah (217) 528-1077</p>
--	--

**(3) ABANDONMENT IN PLACE OF TANKS:**

- (a) Number and size tanks being abandoned:* (TK # 3) - 6,000 gallons
- (b) Location of tanks being abandoned:* **See site plan and contingencies section.**
- (c) Location of piping being abandoned:* **See contingencies section.**

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES: Abandonment material will be cement slurry. Tank #3 is next to (lengthwise end to end) of the in-service tank #1, and the active piping for tank #1 runs over the top of tank #3. The associated piping for tank #3 will be abandoned also, unless it can be physically removed. IEMA #2007-0158, #2004-1608, #2002-0145, #91-0443.**
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<p><b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b></p>	
<p>W J Scott Company          3861 Tozer Road          Springfield, IL 62707</p>	<p>Contact Person: Ronald T Russell          Phone: (217) 787-6081          Contractor Registration #    Exp.</p>

Sincerely,

*James J. Coffey*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 9/10)