



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-007981
Permit # 00898-2011UPG
Request Rec'd 09/09/2011
Amended Date
Approval Date 9/12/2011 JC
Permit Expires 3/12/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: TA Operating, LLC 24601 Center Ridge Road, Suite 200, d/b/a Travel Centers of America, Inc. Westlake, OH 44145 Contact: Tom CareyClark (309) 827-4676	(2) FACILITY - name and address where tanks are located: Monee Stopping Center 5915 Monee Rd, I-57 & Monee Rd Monee, Will Co., IL Contact: Greg McLemen (708) 534-0400
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 13) - 6,000 gallons, (TK # 14, 15) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 13, 14, 15) - (Installing) partial Fiberglass Double Wall Ameron Dualoy 3000/LCX at the immediate localized areas of the new submersible pumps to allow for retrofitting of these new submersible pumps. This partial piping will retrofit to the existing piping just outside of the existing sumps as per site plan (refer to permit #00902-2011UPG for more defined details on the work for this permit). Also, piping at the old E-85 dispenser sump will be re-worked to allow for a new dispenser top replacement, (TK # 13, 14, 15) - (Installing) Other submersible pumps will be installed to replace the old pumps.
- (d) *Product to be stored in each tank:* (TK # 13) - E-85, (TK # 14, 15) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 13, 14, 15) - (Installing) partial Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES:** Contractor states there are existing line leak detectors and existing sump sensors for these tanks and their associated dispenser sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Wood Dale, IL 60191	Contact Person: Jack Meck Phone: Contractor Registration # Exp.
--	---

Sincerely,

