



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-007981
Permit # 00902-2011UPG
Request Rec'd 09/09/2011
Amended Date
Approval Date 9/12/2011 JC
Permit Expires 3/12/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: TA Operating, LLC 24601 Center Ridge Road, Suite 200, d/b/a Travel Centers of America, Inc. Westlake, OH 44145 Contact: Tom CareyClark (309) 827-4676	(2) FACILITY - name and address where tanks are located: Monee Stopping Center 5915 Monee Rd, I-57 & Monee Rd Monee, Will Co., IL Contact: Greg McLemen (708) 534-0400
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 20,000 gallons, (TK # 7, 8) - 10,000 gallons

(b) Type of tanks:

(c) Type of piping: (TK # 4, 7, 8) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX as follows: For tank #4 the new piping will be from the submersible pump to the furthest last three truck dispensers. The piping for tanks 7 and 8 will be manifolded together just outside the submersible sump are. The new piping for tanks #7 and #8 will then travel from the submersible pumps / manifold to a point where the lines will re-connect to the existing product piping that continues just outside of the tank pad area on the other side of the station (see site plan and see permit #00897-2011REM for more info on this), (TK # 4, 7, 8) - (Installing) Other submersible pump to replace the existing pumps.

(d) Product to be stored in each tank: (TK # 4) - Diesel Fuel, (TK # 7, 8) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping: (TK # 4, 7, 8) - (Installing) Mechanical Pressurized Line Leak Detection Vaporless VMI1 99LD 3000. Contractor states there are existing interstitial sensors at each submersible sump and at each dispenser sump.

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4, 7, 8) - (Installing) Fiberglass Non-Corrosive

(g) Spill containment devices, piping, and dispenser containment devices:

(h) Overfill prevention devices:

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Wood Dale, IL 60191	Contact Person: Jack Meck Phone: Contractor Registration # Exp.
--	---

Sincerely,

