



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 2-007981  
Permit # 00897-2011REM  
Request Rec'd 09/09/2011  
Amended Date  
Approval Date 9/12/2011 JC  
Permit Expires 3/12/2012

## Piping removal only

### Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  TA Operating, LLC 24601 Center Ridge Road, Suite 200, d/b/a Travel Centers of America, Inc. Westlake, OH 44145  Contact: Tom CareyClark (309) 827-4676	<b>(2) FACILITY</b> - name and address where tanks are located:  Monee Stopping Center 5915 Monee Rd, I-57 & Monee Rd Monee, Will Co., IL  Contact: Greg McLemen (708) 534-0400
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

### **(3) REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed:* (TK # 7, 8) - 10,000 gallons, (TK # 13) - 6,000 gallons
- (b) *Description/location of piping being removed:* ***Partial piping will be removed for tanks 7 & 8 from the submersibles to just outside of the tank pad that lies on the other side of the station going towards the "car" islands(see site plan). From there, the existing piping will continue to be used. Also, a small localized amount of piping will be removed within the dispenser area only for tank #13 due to the fact this tank will be converting from E-85 to diesel (the contractor is retrofitting for a replacement product dispenser due to this change in product).***
- (c) *Product stored in each tank:* (TK # 7, 8) - Gasoline, (TK # 13) - E-85
- (d) *Reason of tanks being removed:* ***The tanks will remain existing.***
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used:* (TK # 7), (TK # 8), (TK # 13)
- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.
- (5) **SPECIAL CONTINGENCIES:** See permits 00898-2011UPG and 00902-2011UPG for further guidance on this project. This is for the removal of piping only. Contractor states tank #13 will be converting from E-85 to diesel.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Performance Tank, Inc. 730 Creel Drive	Contact Person: Jack Meck Phone:  Contractor Registration #    Exp.
------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------

Sincerely,