

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 4-027774
Permit # 00800-2011UPG
Request Rec'd 08/23/2011
Amended Date
Approval Date 8/23/2011 JC
Permit Expires 2/23/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Casey's Retail Company One Convenience Boulevard, P.O. Box 3001 Ankeny, IA 50021-8045	Casey's General Store #2928 805 S. Sangamon Ave. Gibson City, Ford Co., IL
Contact: Mark Bane (515) 965-6238	Contact: David L. Barker (217) 784-8491

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 3, 4, 5) 10,000 gallons, (TK # 2) 6,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2, 3, 4, 5) (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC to replace all the existing product piping. There will also be an installation of manifold piping between tanks 1 and 2 that will include the appropriate check valves and ball valves, (TK # 1, 2, 3, 4, 5) (Installing) Ameron Fiberglass Single Wall Piping by installing approximately 15' of vent piping to each existing vent line to accommodate the site building extension.
- (d) Product to be stored in each tank: (TK # 1, 2) Diesel Fuel, (TK # 3, 4, 5) Gasoline
- (e) Type of leak detection being used:
 - *Tank:* (TK # 1, 2, 3, 4, 5) (Installing) Automatic Tank Gauging Veeder Root CSLD option only to the existing ATG system (the existing console and probes will remain).
 - *Piping:* (TK # 1, 2, 3, 4, 5) (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all dispenser sumps and all submersible sumps., (TK # 1, 2, 3, 4, 5) (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) Corrosion Protection being used:

Tank:

Piping: (TK # 1, 2, 3, 4, 5) - (Installing) Flexible Non-Corrosive

- (g) Spill containment devices, piping, and dispenser containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
	Contact Person: Tom Oltman Phone:
Washington, IL 61571	Contractor Registration # Exp.

Sincerely,

Jame of Coffey

Fire Department -Office Coordinator -Division File (Rev. - 9/10)