



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 1-010696
Permit # 00745-2011UPG
Request Rec'd 08/08/2011
Amended Date
Approval Date 8/10/2011 JC
Permit Expires 2/10/2012

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Ram S. Lehal          202 South Main Street          Albany, IL 61230</p> <p>Contact: Ram or Sharan Lehal</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Albany Oil, Inc.          202 South Main Street          Albany, Whiteside Co., IL</p> <p>Contact: Ram or Sharan Lehal (309) 887-4393</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 5) - 10,000 gallons, (TK # 6) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 5, 6) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC to replace all the existing primary product piping. Contractor states there is existing 3" double wall secondary chase piping that will remain.
- (d) *Product to be stored in each tank:* (TK # 5, 6) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:*  
*Piping:* (TK # 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS at each dispenser sump only. The contractor states there are existing sensors at the submersible sumps.
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 5, 6) - (Installing) Flexible Non-Corrosive primary product piping. Contractor states there is existing 3" secondary chase piping that will remain.
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p>Blue Grass, IA 52726</p>	<p>Contact Person:</p> <p>Phone:</p> <p>Contractor Registration # Exp.</p>
--	--

Sincerely,

Jim Coffey

