



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 7-023264
Permit # 00759-2011ABN
Request Rec'd 08/09/2011
Amended Date
Approval Date 8/10/2011 JC
Permit Expires 2/10/2012

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Paradigm Properties, Inc. 203 Mill Street New Athens, IL 62264-2112</p> <p>Contact: Zachary Page</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>A J One Stop 147 W. Vienna Street Anna, Union Co., IL</p> <p>Contact: Zack Page (618) 833-3003</p>
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 3) - 2,000 gallons
- (b) Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 2011-0749. See site plan and contingencies section.
- (c) Location of piping being abandoned:* Piping for this tank is being removed under permit #00622-2011REM.

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES:** Fill material will be flowable fill / slurry mix. See permit #00622-2011REM for the removal of this tank's (tank #3) associated piping, and also for tanks and piping for 1,2,4, and 6. UST #3 is half-way under building and cannot be safely / properly removed. The existing UST is under the existing building structure and if removed would cause extreme damage to the structure. The OSFM inspector is on site, which also determined that removing this UST is unsafe.
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>JK-Five Construction, Inc. 2160 E. Enterprise Springfield, IL 62702</p>	<p>Contact Person: Jack Davis Phone: 217-391-2656</p> <p>Contractor Registration # Exp.</p>

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)