



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-000995
Permit # 00736-2011UPG
Request Rec'd 08/05/2011
Amended Date
Approval Date 8/5/2011 JC
Permit Expires 2/5/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ozinga Bros., Inc, 19001 Old LaGrange Road, Suite 300 Mokena, IL 60448 Contact: Barry N. Voorn	(2) FACILITY - name and address where tanks are located: Ozinga Bros., Inc. 200 West Jarvis Avenue Des Plaines, Cook Co., IL Contact: Richard Slager (312) 656-8393
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 11) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 11) - (Installing) Flexible Double Wall OPW Flexworks CP-15 non corrosive from the submersible sump to the first dispenser sump only. This new primary piping will be installed through the existing secondary containment chase duct. The contractor states there are existing sensors at the submersible sump and at the first dispenser sump.
- (d) *Product to be stored in each tank:* (TK # 11) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 11) - (Installing) Flexible Non-Corrosive within the existing fiberglass secondary chase duct piping
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Mokena, IL 60448	Contact Person: Hoyt Ary Phone: Contractor Registration # Exp.
---	--

Sincerely,