



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 1-009852
Permit # 00656-2011ABN
Request Rec'd 07/25/2011
Amended Date
Approval Date 7/27/2011 JC
Permit Expires 1/27/2012

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071 Contact: Arthur J. Johnson (815) 625-6380	(2) FACILITY - name and address where tanks are located: Expresslane Inc. #51 3070 North Illinois Route 71, Route 71 & I-80 Ottawa, LaSalle Co., IL Contact: Roby Donald (815) 434-7581
---	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) Number and size tanks being abandoned:* (TK # 1, 4) - 10,000 gallons
- (b) Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 2007-0514
- (c) Location of piping being abandoned:* **See contingencies section and the site plan.**

- (4)** This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) SPECIAL CONTINGENCIES:** Fill material will be K-crete, concrete with fly ash, flowable motor mix. TK 1 - it is unknown exactly where the tank end is. If it is removed, it may undermine the backfill of the adjacent active tanks. If it is determined by the inspector on site that this tank can be removed, then it must be removed. TK - 4 removal of this tank may undermine the canopy footing that is right next to it. A copy of the site assessment is on file.
- (6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Illowa Enterprises, Inc. 2703 4th Avenue Moline, IL 61265	Contact Person: Rob Vyncke Phone: (309) 762-1729 Contractor Registration # IL-981 Exp.
---	--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)