



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 2-035297
Permit # 00675-2011UPG
Request Rec'd 07/26/2011
Amended Date
Approval Date 7/26/2011 JC
Permit Expires 1/26/2012

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Expressway Stop, Inc. 444 E. New York St. Sugar Grove, IL 60554-4138</p> <p>Contact: Man Singh Das (630) 896-3400</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Expressway Stop 444 E New York & N Root St Aurora, Kane Co., IL</p> <p>Contact: Mohammad Hashmi (630) 892-4200</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1, 2) - 8,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P150SC to replace the manifold section of piping between the submersible pumps for tanks 1 & 2. The existing steel piping within the submersible sumps will be reworked as needed to install this replacement section of manifold piping.
- (d) **Product to be stored in each tank:** (TK # 1, 2) - Gasoline
- (e) **Type of leak detection being used:**
Tank:
Piping: Permit #2018-96UPG indicates there are existing interstitial sensors at the submersible sumps for tanks 1,2,3.
- (f) **Corrosion Protection being used:**
Tank:
Piping: (TK # 1, 2) - (Installing) partial Flexible Non-Corrosive. This portion piping is also contained within existing 4" secondary chase piping.
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overflow prevention devices:**
- (i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>North Aurora, IL 60542-9658</p>	<p>Contact Person: Jason Reed Phone: Contractor Registration # Exp.</p>
---	---

Sincerely,

James J. Coffey

