



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY

Facility # 6-027735
Permit # 00545-2011UPG
Request Rec'd 06/22/2011
Amended Date 07/06/2011
Approval Date 6/22/2011 JC
Permit Expires 12/22/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

Table with 2 columns: (1) OWNER OF TANKS - Corporation, partnership, or other business entity; (2) FACILITY - name and address where tanks are located.

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000 gallons
(b) Type of tanks:
(c) Type of piping: (TK # 1, 2, 3) - (Installing) Flexible Double Wall A.P.T. Poly Tech P150SC to replace all the existing product piping from the tanks throughout all dispensers. , (TK # 1, 2, 3) - (Installing) Submersible Sumps containment FRP, (TK # 1, 2, 3) - (Installing) Other submersible pump to replace the existing pumps.
(d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline
(e) Type of leak detection being used:
Tank:
Piping: (TK # 1, 2, 3) - (Installing) Piping Sump Sensors Interstitial Monitoring Beaudreau S406 Interstitial sensor at all submersible sumps and all dispenser sumps. According to permit #9150-93UPG, there are existing line leak detectors.
(f) Corrosion Protection being used:
Tank:
Piping: (TK # 1, 2, 3) - (Installing) Flexible Non-Corrosive
(g) Spill containment devices, piping, and dispenser containment devices:
(h) Overfill prevention devices:
(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

Table with 1 column: (6) PERSON, FIRM OR COMPANY PERFORMING WORK:
Contact Person:
Phone:
Contractor Registration # Exp.
Belleville, IL 62220

Sincerely,

Handwritten signature of Jim Coffey

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File

