



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 1-013864
Permit # 00521-2013UPG
Request Rec'd 06/04/2013
Amended Date
Approval Date 6/4/2013 JC
Permit Expires 12/4/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Kishwaukee Properties, LLC 3 River Hills Court Bolingbrook, IL 60490 Contact: Abushamat Hekmat	(2) FACILITY - name and address where tanks are located: Kishwaukee Gas Station 2233 Kishwaukee Rockford, Winnebago Co., IL Contact: Abushamat Hekmat
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired:* (TK # 14, 15) - 9,728 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 14, 15) - (Installing) Flex Connector Steel at all submersible sumps and at all dispenser sumps, (TK # 14, 15) - (Installing) Submersible Sumps containment FRP, (TK # 14, 15) - (Installing) Dispenser Sumps containment FRP for all dispensers.

(d) *Product to be stored in each tank:* (TK # 14, 15) - Gasoline

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 14, 15) - (Installing) Fiberglass Non-Corrosive containment sumps for all flex connectors at each submersible pump and all dispensers.

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Mokena, IL 60448	Contact Person: Rick Krol Phone: (708) 478-6190 Ext. 231 Contractor Registration # IL-002275 Exp. 05/21/2014
---	--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)