



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 6-027735
Permit # 00545-2011UPG
Request Rec'd 06/22/2011
Amended Date
Approval Date 6/22/2011 JC
Permit Expires 12/22/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Dickerson Petroleum 920 North Illinois Street Belleville, IL 62220</p> <p>Contact: Tom Waller (618) 233-0786</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Gas Mart 19 10425 Lincoln Trail Fairview Heights, St. Clair Co., IL</p> <p>Contact: Jeremy Wilken (618) 398-0300</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 2) - (Installing) partial section (approximately 27') of Flexible Double Wall OPW Pisces between dispensers 1/2 and 3/4 only. This is to replace the existing leaking double wall flexible section between the above mentioned dispensers. (There is existing single wall steel piping from all three tanks going to just outside of the first dispenser sump area, where the three piping runs then transition to double wall flexible non - corrosive piping).
- (d) *Product to be stored in each tank:* (TK # 2) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping: According to permit #9150-93UPG, there are existing dispenser sump sensors at all three dispensers, and existing line leak detectors.
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 2) - (Installing) partial section of Flexible Non-Corrosive. (See above, and also see the contingencies section).
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	
<p>Belleville, IL 62220</p>	<p>Contact Person: Phone: Contractor Registration # Exp.</p>

Sincerely,

Jim Coffey

