



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 2-015082
Permit # 00531-2011UPG
Request Rec'd 06/15/2011
Amended Date
Approval Date 6/15/2011 JC
Permit Expires 12/15/2011

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overflow prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Algobil Land Corp.          4 Springbrook Court          Streamwood, IL 60107          Contact: Seth Singh</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Algonquin Mobil          609 South Main Street          Algonquin, McHenry Co., IL          Contact: Sharon Ochoa (847) 658-5420</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 7, 8) - 10,000 gallons, (TK # 9, 10) - 5,000 gallons, (TK # 11) - 2,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:**
- (d) **Product to be stored in each tank:** (TK # 7) - Diesel Fuel, (TK # 8, 9, 10) - Gasoline, (TK # 11) - Kerosene
- (e) **Type of leak detection being used:**  
*Tank:* (TK # 7, 8, 9, 10, 11) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 probes and console.  
*Piping:*
- (f) **Corrosion Protection being used:**  
*Tank:*  
*Piping:*
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overflow prevention devices:**
- (i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overflow prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>           Lansing, IL 60438</p>	<p>Contact Person: Ed Angell          Phone:          Contractor Registration # Exp.</p>
--	--

Sincerely,

*James J. Coffey*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 9/10)