



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Extended

FOR OFFICE USE ONLY

Facility # 1-022303
Permit # 01346-2010UPG
Request Rec'd 12/02/2010
Amended Date
Approval Date 12/3/2010 DS
Permit Expires 12/3/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

Table with 2 columns: (1) OWNER OF TANKS - Corporation, partnership, or other business entity; (2) FACILITY - name and address where tanks are located.

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4, 5, 6) - 10,000 gallons
(b) Type of tanks:
(c) Type of piping: (TK # 4, 5, 6) - (Installing) Flexible Double Wall A.P.T. Poly Tech P175SC product piping to replace the existing piping for new islands, and a manifold section of piping for the product lines of tank #4 and #5, (TK # 4, 5, 6) - (Installing) Fiberglass Single Wall vent Piping Ameron if necessary.
(d) Product to be stored in each tank: (TK # 4, 5, 6) - Gasoline
(e) Type of leak detection being used:
Tank:
Piping: (TK # 4, 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in all dispenser sumps and all submersible sumps. The existing line leak detector will remain.
(f) Corrosion Protection being used:
Tank:
Piping: (TK # 4, 5, 6) - (Installing) Flexible Non-Corrosive product piping.
(g) Spill containment devices, piping, and dispenser containment devices:
(h) Overfill prevention devices:
(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

Table with 1 column: (6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Tom Oltman, Phone: (309) 694-8224, Contractor Registration # Exp.

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rov. - 9/10)