



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 6-016583
Permit # 00386-2011REM
Request Rec'd 05/03/2011
Amended Date
Approval Date 5/3/2011 JC
Permit Expires 11/3/2011

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Wolff Oil, Inc. 1511 Old Rte. 66 North, R.R. #3, Box 6 Litchfield, IL 62056 Contact: Johnny Hamilton (217) 324-4086	(2) FACILITY - name and address where tanks are located: 1000 Auto Sales 3rd & Franklin Greenville, Bond Co., IL Contact: Daniel Goggins (618) 664-4357
---	--

(3) REMOVAL OF TANKS:

(a) *Number and size of tanks being removed:* (TK # 3) - 300 gallons, (TK # 4) - 560 gallons, (TK # 5) - 1,000 gallons

(b) *Description/location of piping being removed:*

(c) *Product stored in each tank:* (TK # 3) - Used Oil, (TK # 4, 5) - Gasoline

(d) *Reason of tanks being removed:*

(e) *If tank(s) is leaking, indicate IEMA incident number:*

(f) *Date each tank was last used:* (TK # 3, 4, 5) - 05/01/1998

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Jeff Guisewite, Inc. 16153 East 1100 Road	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)