



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 3-018535
Permit # 00372-2011INS
Request Rec'd 04/28/2011
Amended Date
Approval Date 5/3/2011 JC
Permit Expires 11/3/2011

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Mark Williams 23521 94th Avenue North Port Byron, IL 61275 Contact: Mark Williams (563) 468-1899	(2) FACILITY - name and address where tanks are located: Mark Williams 238 S. State Street Hampton, Rock Island Co., IL Contact: Mark Williams (563) 468-1899
--	--

(3) INSTALLATION OF TANKS:

- (a) **Number and size of tanks being installed:** (TK # 8) - 8,000 gallons, and one compartment tank consisting of: (TK # 9, 10) - 4,000 gallons each.
- (b) **Type of tanks:** (TK # 8, 9, 10) - (Installing) Composite Double Wall Glasteel II
- (c) **Type of piping:** (TK # 8, 9, 10) - (Installing) partial Flexible Double Wall Western Co-Flex from the tanks to the new transition sump where this new piping will connect to the existing double wall fiberglass piping running to the existing two dispensers. There will also be a new siphon bar installed between tank #8 & #9. Tank #8 will not have a submersible pump in it, and consequently no line leak detector.
- (d) **Product to be stored in each tank:** (TK # 8, 9, 10) - Gasoline
- (e) **Type of leak detection being used:**
Tank: (TK # 8, 9, 10) - (Installing) Interstitial Monitoring Incon TS 1001 , (TK # 8, 9, 10) - (Installing) Automatic Tank Gauging Incon TS 1001
Piping: (TK # 8, 9, 10) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TS 1001 at the two existing gasoline dispenser locations (new replacement dispenser tops are being installed also, including a new dispenser top for the diesel island; however, no work will be done below the shear valve for the diesel dispenser), at the new transition sump, and at each submersible sump (to include sensors at the sumps at both ends of the siphon bar). , (TK # 9, 10) - (Installing) Mechanical Pressurized Line Leak Detection Vaporless LD 2200 line leak detector (tank #8 will not have a submersible sump due to siphon bar).
- (f) **Corrosion Protection being used:**
Tank: (TK # 8, 9, 10) - (Installing) Composite Non-Corrosive
Piping: (TK # 8, 9, 10) - (Installing) Flexible Non-Corrosive
- (g) **Spill containment devices, piping and dispenser containment devices:**
- (h) **Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **GENERAL REQUIREMENTS:** There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

(6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Roger L Clark Phone: Contractor Registration # Exp.

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)