



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-021136
Permit # 00343-2011UPG
Request Rec'd 04/21/2011
Amended Date
Approval Date 4/21/2011 JC
Permit Expires 10/21/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Zervos Three, Inc 10051 Irving Park Road Schiller Park, IL 60176 Contact: George Zervos (847) 331-9122	(2) FACILITY - name and address where tanks are located: Mount Prospect Shell 1050 E. Northwest Hwy. Mount Prospect, Cook Co., IL Contact: George Zervos
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 4, 6) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 6) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX from the tank to the diesel dispenser (an existing dispenser island located on the east edge of the property line). The existing manifold between tanks #5 and #6 will be disconnected to accommodate the conversion of tank #6 from gasoline to diesel. The contractor states all main product lines for all three tanks will remain active with existing line leak detectors, and no main piping will be removed. Contractor also states there are existing submersible sumps and dispenser sumps, and all have existing sensors.
- (d) *Product to be stored in each tank:* (TK # 5, 6) - Gasoline (see contingencies section).
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Rockford, IL 61108	Contact Person: Nate Meyer Phone: Contractor Registration # Exp.
---	--

Sincerely,

