

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-002988
Permit # 00325-2011UPG
Request Rec'd 04/18/2011
Amended Date
Approval Date 4/19/2011 JC
Permit Expires 10/19/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
City of Wheaton 303 E. Wesley Wheaton, IL 60187	City of Wheaton 821 W. Liberty Drive Wheaton, Du Page Co., IL
Contact: Joe Knippen (630) 260-2113	Contact: Joe Knippen (630) 260-2113

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7) 15,000 gallons, (TK # 8) 10,000 gallons
- (b) Type of tanks: (TK # 7, 8) (Installing) Other two new replacement FRP submersible sumps, and three new replacement dispenser sumps with dispenser tops. Two new replacement submersible pumps will also be installed.
- (c) Type of piping: (TK # 7, 8) (Installing) Positive Shutoff Valves where needed, (TK # 7, 8) (Installing) Sheer Valves at dispensers, (TK # 7, 8) (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX replacement product piping, (TK # 7, 8) (Installing) Fiberglass Single Wall Piping Ameron replacement piping for the vents and vapor piping, (TK # 7, 8) (Installing) Flex Connector Steel at submersible sumps and dispenser sumps. Also installing new risers with dielectric coating for the fills and probes.
- (d) Product to be stored in each tank: (TK # 7) Gasoline, (TK # 8) Diesel Fuel
- (e) Type of leak detection being used:
 - Tank: (TK #7, 8) (Installing) new sensor module only in the existing TLS 350 tank gauge console.
 - *Piping:* (TK # 7, 8) (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at each submersible sump and all dispenser sumps.
- (f) Corrosion Protection being used:

Tank:

Piping: (TK # 7, 8) - (Installing) Fiberglass Non-Corrosive

- (g) Spill containment devices, piping, and dispenser containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:		
	Contact Person: Phone:	
North Aurora, IL 60542	Contractor Registration # Exp.	

Sincerely,

James of Coffey

Division File (Rev. - 9/10)