



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

**REVISED**

FOR OFFICE USE ONLY  
Facility # 4-017213  
Permit # 00341-2013UPG  
Request Rec'd 04/26/2013  
Amended Date  
Approval Date 4/26/2013 JC  
Permit Expires 10/26/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Murel & Janki, Inc. 1660 Pulaski Street Lincoln, IL 62656 Contact: Reshma Patel (217) 737-5584	<b>(2) FACILITY</b> - name and address where tanks are located: Westville 6 1717 N. State Street Westville, Vermilion Co., IL Contact: Reshma Patel (217) 267-3966
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 10, 11, 12) - 10,000 gallons, (TK # 13, 14) - 7,500 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 10, 11, 12, 13, 14) - (Installing) Dispenser Sumps containment FRP under all dispensers (the existing islands are being re-constructed in the existing location).

(d) *Product to be stored in each tank:* (TK # 10, 11, 12) - Gasoline, (TK # 13, 14) - Diesel Fuel

(e) *Type of leak detection being used:*

*Tank:* (TK # 10, 11, 12, 13, 14) - (Installing) Automatic Tank Gauging Veeder Root TLS 350 **console only** to allow for monitoring of the new dispenser sump sensors.

*Piping:* (TK # 10, 11, 12, 13, 14) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 at all dispenser sumps only.

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Gilman, IL 60938	Contact Person: Charlie Moore Phone: (815) 265-7364  Contractor Registration # IL-1224 Exp.
---	--

Sincerely,