



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 5-001758
Permit # 00247-2011UPG
Request Rec'd 03/24/2011
Amended Date
Approval Date 3/24/2011 JC
Permit Expires 9/24/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: R & L Transfer, Inc. 600 Gillam Road, Wilmington, OH 45177 Contact: John Chapman (800) 830-2343	(2) FACILITY - name and address where tanks are located: R & L Transfer, Inc. 3401 Remington Road Springfield, Sangamon Co., IL Contact: John Chapman (800) 830-2343
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 48,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) partial 3" Fiberglass Secondary Containment Ameron from the eastern most satellite dispenser to the center master dispenser , (TK # 1, 2) - (Installing) partial 2" Fiberglass Double Wall Ameron primary product piping from the eastern most satellite dispenser to the center master dispenser.
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Diesel Fuel
- (e) *Type of leak detection being used:*
Tank:
Piping: (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TSP ULS at the eastern most satellite dispenser sump and at the middle master dispenser sump only.
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 1, 2) - (Installing) partial Fiberglass Non-Corrosive primary piping and secondary containment piping.
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Pekin, IL 61554	Contact Person: Phone: Contractor Registration # Exp.
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)