



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 2-017859
Permit # 00485-2013CAT
Request Rec'd 05/28/2013
Amended Date
Approval Date 5/29/2013 JC
Permit Expires 11/29/2013

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: South Suburban Hospital 17800 South Kedzie Avenue Hazel Crest, IL 60429 Contact: Curly VanSessen (708) 213-3097	(2) FACILITY - name and address where tanks are located: South Suburban Hospital 17800 South Kedzie Avenue Hazel Crest, Cook Co., IL Contact: George Nelson (708) 213-3097
---	---

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 4) - 1,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank:* (TK # 4) - Diesel Fuel

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank: (TK # 4) - (Installing) replacement Sacrificial Anodes (total of 2) Cathodic Protection to replace existing depleted impressed current anodes that are protecting tank #4 per original design specifications (contractor states the piping is existing non-corrosive flexible - see permit #00875-2012UPG).

Piping:

(g) *NACE certified designer:*

Certification number:

(h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: North Aurora, IL 60542	Contact Person: Jason Reed Phone: (630) 375-6121 Contractor Registration # Exp.
---	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)