



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 4-037124
Permit # 00218-2011UPG
Request Rec'd 03/17/2011
Amended Date
Approval Date 3/17/2011 JC
Permit Expires 9/17/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: E K Petroleum, LLC 211 North Market Sullivan, IL 61951 Contact: Jon England (217) 728-7195</p>	<p>(2) FACILITY - name and address where tanks are located: E K Petroleum 211 North Market Street, Sullivan, Moultrie Co., IL Contact: Jon England (217) 728-7195</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 2) - 12,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* Contractor had to uncover the vent line at the tank under emergency repair conditions since the tank was taking on water. Where the vent line comes up to the vent pipe riser, the contractor found the clamps on the existing Environ piping was corroded off at the riser. The contractor installed the correct Environ clamps, air tested the line, and hooked it back up to the tank. The temporary (emergency vent line that was installed to keep the water out) vent line will be removed.
- (d) *Product to be stored in each tank:* (TK # 2) - Gasoline
- (e) *Type of leak detection being used:*
 Tank:
 Piping:
- (f) *Corrosion Protection being used:*
 Tank:
 Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Riverton, IL 62561</p>	<p>Contact Person: Mike Milburn Phone: 217-629-8522 Contractor Registration # Exp.</p>
--	--

Sincerely,

Jim Coffey

