



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

## Amended

FOR OFFICE USE ONLY  
Facility # 4-025546  
Permit # 00480-2013UPG  
Request Rec'd 05/24/2013  
**Amended Date 05/28/2013**  
Approval Date 5/24/2013 JC  
Permit Expires 11/24/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company One Convenience Blvd., Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	<b>(2) FACILITY</b> - name and address where tanks are located: Casey's General Store 508 North State Ridge Farm, Vermilion Co., IL Contact: Dawn Allison (217) 247-2192
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 2) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) partial Flexible Double Wall A.P.T. Poly Tech P175SC from the submersible sumps to the first dispenser sump only.
- (d) *Product to be stored in each tank:* (TK # 1, 2) - Gasoline
- (e) *Type of leak detection being used:*  
*Tank:*  
**Piping: (TK # 1, 2) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 discriminating containment sump sensors at both dispenser sumps and at both submersible sumps to replace the existing non-discriminating sump sensors.**
- (f) *Corrosion Protection being used:*  
*Tank:*  
**Piping: (TK # 1, 2) - (Installing) partial Flexible Non-Corrosive**
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Des Moines, IA 50313	Contact Person: Chuck Hoenig Phone: (515) 264-4361  Contractor Registration # IL-598 Exp.
---	--

Sincerely,