



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 3-007193  
Permit # 00488-2013UPG  
Request Rec'd 05/28/2013  
Amended Date  
Approval Date 5/28/2013 JC  
**Permit Expires 06/11/2013**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  3-E Petroleum, Inc. 7144 Fair Elms Avenue Burr Ridge, IL 60527  Contact: Georges Youssef (630) 926-0051	<b>(2) FACILITY</b> - name and address where tanks are located:  Clark 3508 West Harmon Highway Peoria, Peoria Co., IL  Contact: Fadi Jreij (309) 676-9879
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired:* (TK # 6) - 12,000 gallons
- (b) Type of tanks:*
- (c) Type of piping:* (TK # 6) - (Installing) Flex Connector Steel to replace the existing leaking flex connector at the submersible sump only.
- (d) Product to be stored in each tank:* (TK # 6) - Gasoline
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Washington, IL 61571	Contact Person: Tom Oltman Phone: (309) 694-8224  Contractor Registration # IL-1079 Exp.
---	---

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Division File  
(Rev. - 9/10)