



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-013106
Permit # 00142-2011UPG
Request Rec'd 02/22/2011
Amended Date
Approval Date 2/23/2011 JC
Permit Expires 8/23/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Milprint Illinois, LLC 3550 Moser Street Oshkosh, WI 54901 Contact: Brian Fuhrer	(2) FACILITY - name and address where tanks are located: Milprint Illinois, LLC 5303 St. Charles Road Bellwood, Cook Co., IL Contact: Allison Diddens
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:** (TK # 5, 6, 7, 8, 9) - 2,000 gallons
- (b) Type of tanks:** (TK # 5, 6, 7, 8, 9) - (Installing) Other Fibrelite FRP sump transition sump located next to the building where the piping will transition from underground to above ground inside the building.
- (c) Type of piping:** (TK # 5, 6, 7, 8, 9) - (Installing) Fiberglass Single Wall Piping A.O. Smith for new replacement vent piping, and also for secondary containment of the new underground primary steel product piping from the tanks to the transition sump, (TK # 5, 6, 7, 8, 9) - (Installing) Steel Single Wall Piping primary product piping from the tanks to the transition sump where it will then become above ground piping inside the building
- (d) Product to be stored in each tank:** (TK # 5, 6, 7, 8, 9) - Solvent
- (e) Type of leak detection being used:**
 - Tank:**
 - Piping:** (TK # 5, 6, 7, 8, 9) - (Installing) European with No Test Req Suction, (TK # 5, 6, 7, 8, 9) - (Installing) Piping Sump Sensors Interstitial Monitoring Incon TS 1001 at the transition sump only.
- (f) Corrosion Protection being used:**
 - Tank:**
 - Piping:**
- (g) Spill containment devices, piping, and dispenser containment devices:**
- (h) Overfill prevention devices:**
- (i) Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: North Aurora, IL 60542	Contact Person: Phone: Contractor Registration # Exp.
---	--

Sincerely,

Jim Coffey

