



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-008128
Permit # 00086-2011UPG
Request Rec'd 01/21/2011
Amended Date
Approval Date 1/27/2011 JC
Permit Expires 7/27/2011

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Rawlings Towing 600 W. Irving Park Rd. Bensenville, IL 60106 Contact: Rich Rawlings (630) 860-1278	(2) FACILITY - name and address where tanks are located: Rawlings Towing 600 W. Irving Park Rd. Bensenville, Du Page Co., IL Contact: Rich Rawlings (630) 860-1278
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2, 3) - 10,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2, 3) - (Installing) Flex Connector Steel at the only dispenser that has diesel - from tank #5 connected to it (there are only two gasoline lines going into that same dispenser; therefore, only those two lines will receive the new sheer valves and flex connectors), (TK # 1, 2, 3) - (Installing) Sheer Valves at the only dispenser that has diesel - from tank #5 connected to it (there are only two gasoline lines going into that same dispenser; therefore, only those two gasoline lines will receive the new sheer valves and flex connectors). FYI - The product lines for tanks 1 and 2 are manifolded together back at the tank field area. Also, a new dispenser top will be installed to replace the old top. The diesel line for tank #5 will not be disturbed / broke open. All work will be done for at the dispenser area in question only.
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Mokena, IL 60448	Contact Person: Chris Derro Phone: Contractor Registration # Exp.
---	---

Sincerely,

