

#### Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Jitendra Patel/Shri Balaji Corp. 203 LaSalle Road, Peru, IL 61301	BP Amoco 1352 May Road, Peru, LaSalle Co., IL
Contact: J.C. Patel (815) 212-4830	Contact: J.C. Patel (815) 223-3109

# (3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 6, 7, 8) 12,000 gallons
- (b) Type of tanks:
- (c) Type of piping:
- (d) Product to be stored in each tank: (TK # 6, 7, 8) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

#### (f) Corrosion Protection being used:

*Tank:* (TK # 6, 7, 8) - (Installing) additional Sacrificial Anode Cathodic Protection to the existing Stip 3 tanks only. *Piping:* 

(g) NACE certified designer:

Certification number:

- (h) Method of integrity assessment of tank(s) being used:
- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at <u>www.sfm.illinois.gov</u> or by calling (217)785-1020.

## (5) <u>SPECIAL CONTINGENCIES</u>:

### (6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Art Wentworth Phone:

Contractor Registration # Exp.

Sincerely,

Jame & Coffey

cc: Storage Tank Safety Specialist -Fire Department -Office Coordinator -Division File (Rev. - 9/10)