



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 2-012966
 Permit # 00457-2013UPG
 Request Rec'd 05/22/2013
 Amended Date
 Approval Date 5/22/2013 DS
 Permit Expires 11/22/2013

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Company 33978 N. US Hwy 45, Gages Lake, IL 60030-0089</p> <p>Contact: Mike Graham (847) 223-3710</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Gages Lake Quik Shop 33978 N. US Hwy 45 Gages Lake, Lake Co., IL</p> <p>Contact: Jack Graham (847) 223-3710</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 9) - 2,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 9) - (Installing) Approximately 15' Fiberglass Double Wall A.O. Smith from old K-1 dispenser sump to existing E-85 product piping.
- (d) *Product to be stored in each tank:* (TK # 9) - Kerosene
- (e) *Type of leak detection being used:*
Tank: (TK # 9) - (EXISTING) Automatic Tank Gauging Veeder Root TLS 350
Piping: (TK # 9) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 9) - (Installing) Fiberglass Non-Corrosive
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:* (TK # 9) - (Installing) Overfill Drop Tube Valve OPW 61SOP
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Chicago Heights, IL 60411</p>	<p>Contact Person: Raymond Kirchner Phone: (708) 758-3222 Ext. 12</p> <p>Contractor Registration # Exp.</p>
---	---

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -
 Fire Department -
 Division File
 (Rev. - 9/10)