



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-014412
Permit # 01345-2010TUP
Request Rec'd 12/02/2010
Amended Date
Approval Date 12/2/2010 JC
Permit Expires 6/2/2011

Permit for TOUCH-UP INTERIOR LINING of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to internally line underground storage tank(s) or piping is hereby granted. Such partial interior lining must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. Such partial interior lining shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Formula Auto Corporation 310 West Northwest Highway Mount Prospect, IL 60056 Contact: Joe Pentz (847) 577-5760	(2) FACILITY - name and address where tanks are located: Formula Auto, Inc. 310 West Northwest Highway Mount Prospect, Cook Co., IL Contact: Bob Massey (847) 577-5760
--	---

(3) INTERIOR LINING OF TANKS:

- (a) Number and size of tanks being internally lined:* (TK # 1) - 3,000 gallons, (TK # 2) - 6,000 gallons, (TK # 3, 4) - 4,000 gallons
- (b) Type of tanks:*
- (c) Name of manufacturer of internal lining material:* (TK # 1, 2, 3, 4) Indus. Enviro. Coatings
- (d) Designation of internal lining material:* (TK # 1, 2, 3, 4) EC 125
- (e) Product to be stored in each tank:* (TK # 1) - Diesel Fuel, (TK # 2, 3, 4) - Gasoline
(Internal lining material must be compatible with product stored in each tank)
- (f) Percentage of each tank being partially lined:* Contractor states no more than 5% of each tank will be touched up.
(Lining Touch-up cannot exceed 5% of entire tank)

- (4) This permit is VOID if tank is unacceptable for touch-up of interior lining. Any tank that has been out of service for a twelve month consecutive period cannot be put back into service unless it meets all new UST upgrade regulations. This permit is for touch-up of interior lining only. Separate permits are required to do interior tank lining inspections or installations of manways.**
- (5) The owner must notify this Office when completion of tank internal lining touch-up has occurred, on the Notification Form for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**
- (6) SPECIAL CONTINGENCIES: Contractor states no more than 5% of each tank will be touched up. Contractor states there are existing manways. The underground storage tank system for tank #6 must be compatible with E-85, as indicated in section 175.400(a) and (c), 175.415(b) and (c), 175.420(a) and (c), 175.630(d)(2) and (j), 175.640(e), and 176.420(a) and (b) of Title 41 of the Illinois Administrative Code.**

<u>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Chicago Tank Lining, Inc. 600 Hartrey	Contact Person: Phone: Contractor Registration # Exp.
--	--

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)