



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 2-044827
Permit # 01306-2010ABN
Request Rec'd 11/18/2010
Amended Date
Approval Date 11/18/2010 JC
Permit Expires 5/18/2011

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Rock-Wil Corporation 1761 Glenview Road Glenview, IL 60025 Contact:</p>	<p>(2) FACILITY - name and address where tanks are located: Austin / Custer Building 701-709 Austin Street Evanston, Cook Co., IL Contact:</p>
--	---

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 1) - 550 gallons
- (b) *Location of tanks being abandoned:* See contingencies section.
- (c) *Location of piping being abandoned:*

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES: Tank is located next to building foundation (within 5') and may undermine foundation if removed. Low strength concrete slurry mix will be used. Copy of site assessment is on file. All future permit applications must include (1) original and (2) copies, as indicated at the top of the permit application.**
- (6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.**

<p>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>R. W. Collins Company 7225 West 66th Street Chicago, IL 60638</p>	<p>Contact Person: Ann Collins Phone: (708) 458-6868 Contractor Registration # IL-772 Exp.</p>

Sincerely,

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)